



EURO ENVIRONMENTAL LTD

Creating a safer working environment

Results for legionella samples taken for Jewel Saffire products

EURO ENVIRONMENTAL LTD

Environmental & Occupational Hygiene Consultants

HSE Licence No. 4000404397

VAT No. 728 0110 69

Registered In England No. 3525782

www.euroenvironmental.co.uk

HEAD OFFICE

Atlas 6
Balby Carr Bank
Doncaster
DN4 5JT
Tel: 0870 701 9170
Fax: 0870 701 9171

MIDLANDS OFFICE

Regus Building
Central Boulevard
Blythe Valley Park
Solihull
B90 8AG
Tel: 01564 711187
Fax: 01564 711001

NORTH WEST OFFICE

Cinnamon House
Cinnamon Park
Crab Lane
Fearnhead
Warrington
WA2 0XP

Tel: 01925 661738
Fax: 01925 661800



Analysis of legionella samples taken from water based extinguishers showed no signs of legionella developing. The samples, taken after 6 months of being positioned in a standard office setting at approximately 20-23°C, were analysed by a UKAS accredited laboratory and returned negative for all legionella serogroups.

Further Analysis undertaken after 1 year in a similar environment also returned negative results for all serogroups of legionella and therefore we are very confident that the water based extinguishers are unlikely to develop legionella bacteria when used in a normal workplace environment.

In the unlikely event that legionella were to develop within the extinguishers it should be taken that the risk of fire is much greater than the risk of catching legionnaires disease and the extinguishers should be used.

Full breakdown of the analysis is provided on the sample results sheets attached.

Dean McFarlane

Senior Legionella Consultant

Euro Environmental